

Delmarva Drilling Co., Inc.

P. O. BOX 125

BRIDGEVILLE, DELAWARE 19933

A SUBSIDIARY OF
C. SCHULTES & SONS, INC.

Water Well Contractors

CUSTOMER Sea Colony, Inc. JOB 983
 ADDRESS South Bethany Beach, Dela. DATE 7/27/71
 LOCATION _____

| GROUND | FEET FROM GROUND SURFACE | | WELL LOG |
|--------|--------------------------|--|-------------------------------------|
| | 0 TO..... | | |
| | 0 - 1 | | top soil |
| | 1 - 18 | | fine to coarse tan sand |
| | 18 - 57 | | fine to med gray sand w/5% clay |
| | 57 - 187 | | fine to coarse gray sand |
| | 187 - 240 | | fine to coarse gray sand w/10% clay |
| | 240 - 251 | | fine to med gray sand w/5% clay |
| | 251 - 321 | | fine to coarse gray sand |
| | 321 - 351 | | blue clay |
| | 351 - 418 | | fine to coarse green sand |
| | 418 - 460 | | green clay w/fine sand |
| | | | |

| | | |
|---|------------------------------------|--------------------------------------|
| WELL NO. _____ | DIAMETER OF WELL <u>8"</u> | DEPT OF WELL <u>366'</u> |
| HRS. PUMPED <u>24</u> | SLOT SIZE <u>.020</u> | TYPE OF CASING <u>Steel</u> |
| CAPACITY G.P.M. <u>205</u> | DRILLING MACHINE NO. <u>D-3</u> | LENGTH OF CASING <u>341'</u> |
| STATIC LEVEL <u>8" above ground level</u> | DRILLER <u>E. Kelley</u> | DISTANCE TO TOP OF SCREEN <u>25'</u> |
| PUMPING LEVEL <u>52'2</u> | GRAVEL _____ | TYPE SCREEN <u>Stainless Steel</u> |
| SPECIFIC CAPACITY <u>3.97</u> | BAGS OF CEMENT _____ | SIZE OF SCREEN <u>8"</u> |
| PUMPED WITH <u>Turbine</u> | DATE WELL COMPLETED <u>7/27/71</u> | |

WELL DRILLER SIGNATURE