

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

2/18

WELL COMPLETION REPORT

Q 42-20

1. Permit Number: WRD-6-1532
 Owner of Well: Gray

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 156 feet
 Date Completed 12/7/72

4. Grout: Type Asph. Cement
 from 0 feet to 3.2 feet
 from feet to feet

5. Casing: Type PVC
2 inches to 151 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
151 feet to 156 feet

7. Gravel Packed? Yes No
155 feet to 154 feet

8. Well Head Completion:
Picless Adapter Type
 inches above grade

9. Static Water Level:
1 feet below grade
 feet above grade

10. Pumping Water Level:
25 feet below grade after
3 hours at 50 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity 25 GPM

12. Well Number
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
on soil	0	1
fine tan sand	1	7
fine to coarse white sand	7	14
fine gray sand w/ gray clay	14	40
gray clay	40	60
fine to coarse gray sand	60	84
gray clay	84	92
fine to coarse gray sand	92	157
fine sand w/ gray clay	157	160

14. Signature of Water Well Contractor Dennis Drilling Co Date Jan 15, 1973