

WELL COMPLETION REPORT

TYPE OF PERMANENT PUMP INSTALLED

WELL NO: 61503
 LOCAL ID: _____
 WELL NAME: William, Jewel R.
 INSTALLATION DATE: 7-1-85
 PURPOSE: PERMANENT

PUMP MANUFACTURE: _____
 RATED CAPACITY (GPM): _____
 PUMP INTAKE SETTING: _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

- | | | |
|--|-------------------------------------|--------------------------|
| | YES | NO |
| A. AT LEAST 5' FROM ANY OVERHANG | <input type="checkbox"/> | <input type="checkbox"/> |
| B. AT LEAST 60' FROM ANY SEPTIC TANK | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| C. AT LEAST 10' FROM TOWN SEWER LINE | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD | <input type="checkbox"/> | <input type="checkbox"/> |

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS 100' FROM COMPLETED WELL.
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

- USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO
 ABANDONMENT DATE FOR OLD WELL: _____
 ABANDONMENT METHOD: _____

DRILLING METHOD

- AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED: 155

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	<u>17</u>			
D. G BOTTOM	<u>149</u>			
CASING DIAMETER	<u>2</u>			
CASING MATERIAL	<u>PVC</u>			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	<u>149</u>			
SCREEN BOTTOM	<u>155</u>			
SCREEN DIAMETER	<u>2"</u>			
SCREEN MATERIAL	<u>PVC</u>			

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE AQUIFER MUST BE OBTAINED FROM DNRFC.

GROUT TYPE: CEMENT BENTONITE CLAY
 OTHER: _____

FROM _____ TO _____ FEET
 NON-GROUT BACKFILL OF WELL ANNULUS TYPE: fine FROM 9 TO 147 FEET

GRAVEL PACK: TYPE 3/32"
 FROM 147 TO 155 FEET

STATIC WATER LEVEL: DATE 7-1-85
6.2 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 18 FT. BELOW GRADE
 AFTER 2 HOURS AT 65 GPM.

WELL HEAD COMPLETION:
 PITLESS ADAPTOR
 OTHER _____
12 INCHES ABOVE GRADE.

RECEIVED

FEB 5 1986

WATER SUPPLY

Q: 42-44

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRAT
white fine med sand	0	22
gray clay	22	36
white fine med sand	36	44
gray clay	44	51
lt. med. fine to coarse		
fairly clean sand	51	75
gray clay med	75	96
wh. fine to coarse sand gravel		112
gray clay	112	123
fine to coarse sand	123	157

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME White Drilling Corp
 SIGNATURE OF DRILLER IN CHARGE: William White Sr. DATE: 1/16/83