

068346

LOCAL ID

NAME Mr. Laughlin

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE GOULDS
RATED CAPACITY (GPM) 25
PUMP INTAKE SETTING 100 FT. BELOW GRADE

INSTALL DATE 7-8-87
TEST PERMANENT

THE COMPLETED WELL IS?

TESTIC AGRICULTURAL
COMMERCIAL INDUSTRIAL
EDUCATION PUBLIC
WATER SUPPLY DEWATERING
PUMP RECHARGE HEAT PUMP SUPPLY

A. AT LEAST 5' FROM ANY OVERHANG YES NO
B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
C. AT LEAST 10' FROM TOWN SEWER LINE YES NO
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

REPLACEMENT WELL? YES NO
INSTALL DATE FOR OLD WELL N/A
INSTALL METHOD N/A

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS 15' FROM COMPLETED WELL **CITY SEWER**
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? YES NO
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

DRILLING METHOD

BORED CABLE TOOL
 JETTED AIR ROTARY
 REVERSE WASHED

BEB Q; 42-47
068346

DEPTH DRILLED 120'

RECEIVED

JUL 14 1987

WATER SUPPLY

CASING SEQUENCE

DEPTH	DIAMETER	TYPE
2' ABOVE GRADE		
115'	4"	SCH 40 PVC

SCREEN SEQUENCE

DEPTH	DIAMETER	TYPE
115'		
120'	4"	SCH 40 PVC

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE ADD-IFER MUST BE OBTAINED FROM DWRDC

CEMENT BENTONITE CLAY

TO 20 FEET
BACKFILL OF WELL ANNULUS
FROM 20 TO 113 FEET
TYPE MOBILE 172
TO 120 FEET
INSTALL DATE 7-8-87

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
topsoil	0	1
brn clay	1	3
brn red mud	3	25
gray clay shell	25	50
gray red mud	50	70
gray clay	70	85
gray red mud	85	120

(low, above) GROUND SURFACE
WATER LEVEL: 12 FT. BELOW GRADE
HOURS AT 40 GPM.

COMPLETION:
3" ADAPTOR
CASING
3" ABOVE GRADE.

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF 1 PAGES
COMPANY NAME LARSON WELLS
SIGNATURE OF DRILLER IN CHARGE: John Huff DATE 7-13-87