

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

WELL COMPLETION REPORT

1. Permit Number: 36957
 Owner of Well: Mary Stess

2. Test Well
 Observation Well:
 Production Well:
 Well Abandoned? Yes No

3. Total Well Depth: 142 feet
 Date Completed: _____

4. Grout: Type None
 from _____ feet to _____ feet
 from _____ feet to _____ feet

5. Casing: Type Galv. Steel
2 inches to 127 feet
 inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
137 feet to 142 feet

7. Gravel Packed? Yes No
135 feet to 142 feet

8. Well Head Completion:
 Pitless Adapter _____ Type _____
12 inches above grade

9. Static Water Level:
3 feet below grade
 _____ feet above grade

10. Pumping Water Level:
27 feet below grade after
2 hours at 35 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

QJ52-10

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top soil & fill dirt	2	2
old marl sand	2	4
Clayey light gray sand	5	9
very fine yellow sand & silt	3	12
very fine clayey gray sand & silt	21	33
gray clay	8	41
silty sandy grayish-white clay	17	58
very fine to very coarse white sand & gravel	57	115
very fine to very coarse grayish-white sand	20	135
very fine to very coarse white sand	7	142

14. Signature of Water Well Contractor Date

P.E. White + Sons Inc. Aug 31, 1976

(over)

LLING

Year

TO REMEMBER / 1976
 MS 14

WER
 24

If available) use a well as directed. The following

number: 36957
 date: 8-3-76