

W

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 91712 LOCAL ID 319

OWNER ROBERT ANGELO

CONSTRUCTION DATE 8-11-92

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 OBSERVATION DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL 8-11-92

ABANDONMENT METHOD ben

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED _____

CASING SEQUENCE

	INNER	OUTER
CASING TOP	<u>51</u>	
CASING BOTTOM	<u>250</u>	
CASING DIAMETER	<u>4</u>	
CASING MATERIAL	<u>pcu</u>	

SCREEN SEQUENCE

	INNER	OUTER
SCREEN TOP	<u>250</u>	
SCREEN BOTTOM	<u>260</u>	
SCREEN DIAMETER	<u>2"</u>	
SCREEN MATERIAL	<u>pcu</u>	

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQUIFER
 MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____
 FROM 0 TO 250 FEET

NON-GROUT BACKFILL OF WELL ANNULUS
 TYPE _____ FROM _____ TO _____ FEET

GRAVEL PACK: TYPE # well sand
 FROM 250 TO 260 FEET

STATIC WATER LEVEL: DATE 8/11/92
8 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 8 FT. BELOW GRADE
 AFTER 2 HOURS AT 40 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER _____
 _____ INCHES ABOVE GRADE.

REGISTRATION
 SEP 24 1992

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

YES NO
 A. AT LEAST 15' FROM ANY FOUNDATION
 B. AT LEAST 50' FROM ANY SEPTIC TANK
 C. AT LEAST 10' FROM TOWN SEWER LINE
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS _____ FROM COMPLETED WELL. CENTRAL
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

Qj 52-25

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top of mass + mass	0	3
second clay	3	11
clay - grey	11	16
Sand red fine gr	16	20
Sand med gr	20	180
silt gy	180	185
clay Sand fine gr	185	205
clay gy	205	215
silt gy	215	248
Sand med gy	248	260

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF _____ PAGES
 COMPANY NAME Weymouth Well Drilling Inc
 SIGNATURE OF DRILLER IN CHARGE: Weymouth DATE 8/11/92