

LOCAL ID 17
 Name Ronald O'Connor
 DATE 3/22/88
 PERMANENT
 AGRICULTURAL
 INDUSTRIAL
 PUBLIC
 DEWATERING
 HEAT PUMP SUPPLY
 OTHER (Specify) _____
 REPLACEMENT WELL? YES NO
 START DATE FOR OLD WELL N/A
 START METHOD _____

DRILLING METHOD
 BORED CABLE TOOL
 JETTED AIR ROTARY
 REVERSE WASHED
 OTHER (Specify) _____
 TYPE DRILLED 143

CASING SEQUENCE

INNER	OUTER
133	
2	
Pre	

SCREEN SEQUENCE

INNER	OUTER
133	
143	
4	
Pre	

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE ADAPTER MUST BE OBTAINED FROM DWRFC

CEMENT BENTONITE CLAY
 FROM 0 TO 120 FEET
 TYPE OF WELL ANNULUS U/A
 FROM _____ TO _____ FEET
 SICK TYPE H-2 Marie
 TO 143 FEET
 TEST LEVEL DATE 3-15-88
 (Below, above) GROUND SURFACE
 WATER LEVEL: 15 FT. BELOW GRADE
12 HOURS AT 30 GPM.

LEAD COMPLETION: _____
 LESS ADAPTOR
 FEET ABOVE GRADE _____

TYPE OF PERMANENT PUMP INSTALLED: _____
 PUMP MANUFACTURE N/A
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE
THE COMPLETED WELL IS?
 YES NO
 A. AT LEAST 15' FROM ANY FOUNDATION
 B. AT LEAST 50' FROM ANY SEPTIC TANK
 C. AT LEAST 10' FROM TOWN SEWER LINE
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD
THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS 100' FROM COMPLETED WELL
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS _____

73267

QJ 52-43

RECEIVED
 MAR 25 1988
 WATER SUPPLY

TAK
 04/11/00
 CC
 (K)

205 101

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
tan sand & clay	1	7
brown sand - fine	7	26
white sand w/ grey clay	26	43
red white sand	43	74
red - coarse tan sand	74	103
fine grey sand	103	112
fine grey sand	112	124
red - coarse white sand	124	143

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME Delmar Drilling Co, Inc
 SIGNATURE OF DRILLER IN CHARGE Ronald O'Connor DATE 3/24/88