

13028 LOCAL ID 14  
 Taylor Construction  
 DATE 3/23/88  
 PERMANENT  
 DOMESTIC  
 COMMERCIAL  
 IRRIGATION  
 MONITOR  
 WATER PUMP RECHARGE  
 WATER (Specify)  
 PLACEMENT WELL? YES  NO   
 START DATE FOR OLD WELL 2/10  
 START METHOD

**DRILLING METHOD**  
 BORED  CABLE TOOL  
 JETTED  AIR ROTARY  
 REVERSE  WASHED  
 SPECIFY  
 DEPTH DRILLED 100'

**CASING SEQUENCE**

INNER	OUTER
8.6	
7.0	

**SCREEN SEQUENCE**

INNER	OUTER
8.6	
100	
4	
PVC	

WRITTEN APPROVAL FOR SCREENING/  
 GRAVEL PACKING MORE THAN ONE AQU-  
 IFER MUST BE OBTAINED FROM GNRDC

CEMENT  BENTONITE CLAY   
 0 TO 50 FEET  
 BACKFILL OF WELL ANNULAR SPACE  
 1A FROM TO FEET  
 DRILL TYPE #2 MOBILE  
 TO 100 FEET  
 WATER LEVEL: DATE 3/23/88  
 (below, above) GROUND SURFACE  
 WATER LEVEL: 100 FT. BELOW GRADE  
 HOURS AT 40 GPM.


WELL COMPLETION:  
 ADAPTOR   
 FEET ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:  
 PUMP MANUFACTURE Progress  
 RATED CAPACITY (GPM)  
 PUMP INTAKE SETTING 50 FT. BELOW GRADE

**THE COMPLETED WELL IS?**

	YES	NO
A. AT LEAST 15' FROM ANY FOUNDATION	<input checked="" type="checkbox"/>	<input type="checkbox"/>
B. AT LEAST 50' FROM ANY SEPTIC TANK	<input checked="" type="checkbox"/>	<input type="checkbox"/>
C. AT LEAST 10' FROM TOWN SEWER LINE	<input checked="" type="checkbox"/>	<input type="checkbox"/>
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD	<input checked="" type="checkbox"/>	<input type="checkbox"/>

**THE NEAREST NEIGHBORS (CIRCLE ONE)**  
 SEPTIC TILE FIELD CESSPOOL OR PRIVY  
 IS 100' FROM COMPLETED WELL.  
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?    
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



Q; 52-65

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
top soil	0	1
Fine-med tan sand	1	18
Fine-med tan sand	18	22
Fine-med tan sand	22	30
Fine-med tan sand with green clay	30	42
Very green sand	42	58
Med. coarse clay	58	60
Med. coarse clay	60	80
tan coarse sand with gravel	80	105
tan coarse sand & gravel streaks of clay	105	108

SUPPLEMENTAL DRILLERS LOG ATTACHED YES  NO   
 PAGE 1 OF 1 PAGES  
 COMPANY NAME Dolmar Drilling Co  
 SIGNATURE OF DRILLER IN CHARGE Rexette DeLoe  
 DATE 3/27/88