

WELL COMPLETION REPORT

1. Well Number: 3454
 Owner of Well: Harry Adams

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 60 feet
 Date Completed 8-12-75

4. Grout: Type Cement
 from 3 feet to 15 feet
 from feet to feet

5. Casing: Type PVC
2 inches to 55 feet
 inches to feet
 Drive Shear? Yes No

6. Screen Setting:
55 feet to 60 feet

7. Gravel Packed? Yes No
53 feet to 60 feet

8. Well Head Completion:
NO Plugless Adapter Type
12 inches above grade

9. Static Water Level:
10 feet below grade
 feet above grade

10. Pumping Water Level:
25 feet below grade after
1 hours at 75 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

Rc 34-01

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top Soil	0	1
lt. brn sand - med	1	12
brn clay	12	18
brn sand - med	18	27
gray clay	27	32
brn clay	32	40
brn sand - med	40	50
brn sand - coarse	50	60

14. Signature of Water Well Contractor Edgar Well Driller Date 12-12-75