

1. Permit Number: 37787
 Owner of Well: LARRY Hill

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 63 feet
 Date Completed 5-10-77

4. Grout: Type Best
 from 5 feet to 28 feet
 from _____ feet to _____ feet

5. Casing: Type PVC
2 inches to 63 feet
 _____ inches to _____ feet
 Drive Shoe? Yes No

6. Screen Setting:
56 feet to 63 feet

7. Gravel Packed? Yes No
53 feet to 63 feet

13. Well Log

8. Well Head Completion:
 Picless Adapter _____ Type _____
12 inches above grade

9. Static Water Level:
6 feet below grade
 _____ feet above grade

10. Pumping Water Level:
17 feet below grade after
4 hours at 30 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

12. Well Number _____
 (Leave Blank)

WATER SUPPLY BRANCH

OCT 17 1977

Rd13-06

Formation	Thickness of Stratum	Depth to Bottom of Stratum
TOP SOIL	2	2
TAN clay	2	15
TOP white SAND	15	30
" TAN SAND	33	63

14. Signature of Well Contractor [Signature] Date 5-20-77