

1. Well Number: 38119
 Name of Well: La Sawls

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 63 feet
 Date Completed 5/3/77

4. Grout: Type Cement
 from 3 feet to 15 feet
 from feet to feet

5. Casing: Type PVC
0 inches to 58 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
58 feet to 63 feet

7. Gravel Packed? Yes No
55 feet to 63 feet

8. Well Head Completion:
12 Pile-on Adapter
 inches above grade

9. Static Water Level:
9 feet below grade
 feet above grade

10. Pumping Water Level:
18 feet below grade after
1 hour at 177 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

Rd 21-03

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top Soil	0	1
Tannest Clay	1	20
Gray Clay	31	33
Gray sandy clay	23	34
tan sand. silt	34	40
lt tan sand-filled	40	52
tan sand. silt	52	63

Signature of Water Well Contractor
Chris David Smith

Date
5/3/77