

WELL COMPLETION REPORT

Well Number: 37017
 Name of Well: James Cardrey

Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

Total Well Depth 94 feet
 Date Completed 9-20-76

Grout: Type Cement
 from 3 feet to 15 feet
 from feet to feet

Casing: Type PVC
0 inches to 87 feet
 inches to feet

Drive Shoe? Yes No

Screen Setting:
5 feet to 94 feet

Gravel Packed? Yes No
87 feet to 94 feet

Well Log

8. Well Head Completion:
PVC Pitless Adapter Type
 inches above grade

9. Static Water Level:
10 feet below grade
 feet above grade

10. Pumping Water Level:
16 feet below grade after
1 hours at 55 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

Re 21-07

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Top Soil	0	1
15 Top sand fine	1	4
brn sand Med.	4	5
lt brn clay	5	15
lt brn sand med fine	15	50
15 Top sand - Med fine	50	87
brn sand Med	87	94