

WELL COMPLETION REPORT

OWNER HEARN, James  
 LOCAL ID \_\_\_\_\_  
 CONSTRUCTION DATE 7-29-85  
 PURPOSE  TEST  PERMANENT

USE  DOMESTIC  AGRICULTURAL  
 COMMERCIAL  INDUSTRIAL  
 IRRIGATION  PUBLIC  
 MONITOR  DEWATERING  
 HEAT PUMP RECHARGE  HEAT PUMP SUPPLY  
 OTHER (Specify) check and finish

IS THIS A REPLACEMENT WELL? YES  NO   
 ABANDONMENT DATE FOR OLD WELL day of drilling  
 ABANDONMENT METHOD connect & seal

DRILLING METHOD

AUGERED  BORED  CABLE TOOL  
 DRIVEN  JETTED  AIR ROTARY  
 MUD ROTARY  REVERSE  WASHED  
 OTHER (Specify) \_\_\_\_\_

TOTAL DEPTH DRILLED 60

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	0'			
SING BOTTOM	55'			
CASING DIAMETER	3"			
CASING MATERIAL	SCH 40 PVC			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	55'			
SCREEN BOTTOM	60'			
SCREEN DIAMETER	3"			
SCREEN MATERIAL	SCH 40 PVC			

WRITTEN APPROVAL FOR SCREENING/  
 GRAVEL PACKING MORE THAN ONE FOOT  
 DEEPER MUST BE OBTAINED FROM STATE

GROUT TYPE CEMENT  BENTONITE CLAY   
 OTHER: \_\_\_\_\_

FROM 3 TO 20 FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE cuttings FROM 20 TO 53 FEET

GRAVEL PACK TYPE marble 1/2"

FROM 53 TO 60 FEET

STATIC WATER LEVEL DATE 7-29-85

9 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL 12 FT BELOW GRADE

AFTER 1 HOURS AT 60 GPM

WELL HEAD COMPLETION:  
 PE. PITLESS ADAPTOR   
 OTHER  CASING  
12 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED

PUMP MANUFACTURE \_\_\_\_\_  
 RATED CAPACITY (GPM) N/A  
 PUMP INTAKE SETTING \_\_\_\_\_ FT. BELOW GRADE

THE COMPLETED WELL IS?

A. AT LEAST 5' FROM ANY OVERHANG  YES  NO  
 B. AT LEAST 50' FROM ANY SEPTIC TANK  YES  NO  
 C. AT LEAST 10' FROM TOWN SEWER LINE  YES  NO  
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD  YES  NO

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY  
 IS 100' FROM COMPLETED WELL.  
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?  YES  NO  
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RECEIVED  
 AUG 14 1985  
 WATER SUPPLY

Re 31-01  
 PIT

DRIERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Topsoil	0	1
limed sand	1	5
limed clay	5	14
lt limed sand	14	35
lt limed sand/clay	35	45
limed sand	45	60

SUPPLEMENTAL DRIERS LOG ATTACHED YES  NO   
 DATE OF / PAGE \_\_\_\_\_  
 COMPANY NAME LARSON WELLS, INC  
 SIGNATURE OF DRILLER IN CHARGE John Hearn DATE 8-6-85