

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WELL COMPLETION REPORT

Permit Number: 35209
 Name of Well: Bentley Cont. Co.
 Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

Total Well Depth 31 feet
 Date Completed 11-25-75

Drout: Type ROPE
 from feet to feet
 from feet to feet

Casing: Type 2" PVC
0 inches to 31 feet
 inches to feet
 Drive Shoe? Yes No

Screen Setting: 26 feet to 31 feet

Travel Packed: Yes No
24 feet to 31 feet

9. Well Head Completion: 900 Picolog Adapter Type
 inches above grade

9. Static Water Level: 5 feet below grade
 feet above grade

10. Pumping Water Level: 10 feet below grade after 2 hours at 80 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM
 12. Well Number
 (Leave Blank)

Well Log	Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>White Clay</u>		<u>11'</u>	<u>11'</u>
<u>medium fine white sand + white clay</u>		<u>9'</u>	<u>20'</u>
<u>1" white sand</u>		<u>10'</u>	<u>30'</u>
<u>2" 100</u>		<u>1'</u>	<u>31'</u>

WRD-2
 7/69
 1975