

1. Permit Number: 35150
Owner of Well: 11111

2. Test Well
Observation Well
Production Well
Well Abandoned? Yes No

3. Total Well Depth 60 feet
Date Completed 5/10/77

4. Grout: Type Cement
from 5 feet to 15 feet
from _____ feet to _____ feet

5. Casing: Type PVC _____ feet
0 inches to 55 feet
_____ inches to _____ feet
Drive Shoe? Yes No

6. Screen Setting: _____ feet
55 feet to 60 feet

7. Gravel Packed? Yes No
53 feet to 60 feet

8. Well Head Completed Using
Roll Hollow Adapter
_____ inches above grade

9. Static Water Level:
8 feet below grade
_____ feet above grade

10. Pumping Water Level:
15 feet below grade after
1 hour at 55 GPM

11. Permanent Pump Installed?
Yes No
a. Shallow Well _____ Rotary
Deep Well _____ Jet
b. Reciprocating _____
Centrifugal _____
Submersible _____
c. Capacity _____ GPM

12. Well Number _____
(Leave Blank)

RH15-07

Formation	Thickness of Stratum	Depth to Bott Stratum
<u>Top Soil</u>	<u>0</u>	<u>1</u>
<u>Top Sand - fine</u>	<u>1</u>	<u>8</u>
<u>fine clay</u>	<u>8</u>	<u>9</u>
<u>fine Sand - Med</u>	<u>9</u>	<u>15</u>
<u>Coarse Sand - fine</u>	<u>15</u>	<u>20</u>
<u>gray clay</u>	<u>20</u>	<u>50</u>
<u>gray clay & shell</u>	<u>30</u>	<u>53</u>
<u>light gray Sand - Med coarse</u>	<u>53</u>	<u>60</u>

Signature of Water Well Contractor _____

Date _____
