Rh 21-3

319

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WRD-9
11/68

WELL COMPLETION REPORT

1. Permit Number: WR-6-309
   Well Owner: Gerald E. McCabe

2. Test Well ____
   Observation Well ____
   Production Well X
   Well Abandoned? Yes ____ No ____

3. Well Depth: 94 ft.
   Date Completed: 11-1-68

4. Grout: Type No
   from ____ ft. to ____ ft.
   from ____ ft. to ____ ft.

5. Casing: Type Galv Iron
   0 in. to 94 in. ft.
   ____ in. to ____ in.
   Drive Shoe? Yes ____ No X

6. Screen: Slot Size #10
   88 ft. to 94 ft.

7. Gravel Packed:
   0 ft. to 94 ft.

8. Well Head Completion:
   X Pitless Adapter
   ____ inches above grade

9. Static Water Level:
   7 feet below grade

10. Pumping Level:
    7 ft. after ____ hrs.
    at ____ GPM

11. Capacity of Permanent Pump:
    5 GPM

12. Well Number: ____
    (leave blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
SAND - CLAY	21	21
SAND	21	42
SAND CLAY	21	63
SAND	31	94

14. Signature of Water Well Contractor
    Charles Dairey
    by L.T.M.

    Date 11-29-68

(over)