

66389 LOCAL ID
 Garmonville Nursery
 4/14/86 PERMANENT

TEST
 DOMESTIC
 COMMERCIAL
 IRRIGATION
 MONITOR
 HEAT PUMP RECHARGE
 AGRICULTURAL
 INDUSTRIAL
 PUBLIC
 DEWATERING
 HEAT PUMP SUPPLY
 OTHER (Specify)
 REPLACEMENT WELL? YES NO
 EVENT DATE FOR OLD WELL N/A
 EVENT METHOD

DRILLING METHOD
 BORED
 JETTED
 REVERSE
 CABLE TOOL
 AIR ROTARY
 WASHED
 Specify 98'
 H DRILLED

CASING SEQUENCE
 80'
 60'
 PVC

SCREEN SEQUENCE
 68'
 41'
 PVC

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQU-
 IFER MUST BE OBTAINED FROM DNREC.

CEMENT BENTONITE CLAY
 50.0 TO 58' FEET
 T BACKFILL OF WELL ANNULUS
 CLAY FROM 0 TO 50' FEET
 CK: TYPE #2
 50' TO 98' FEET
 TER LEVEL: DATE 7/24/86
 Below, above) GROUND SURFACE
 WATER LEVEL: 17 FT. BELOW GRADE
 HOURS AT 60 GPM.

AD COMPLETION:
 ESS ADAPTOR
 ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:
 PUMP MANUFACTURE N/A
 RATED CAPACITY (GPM)
 PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

YES NO
 A. AT LEAST 5' FROM ANY OVERHANG
 B. AT LEAST 50' FROM ANY SEPTIC TANK
 C. AT LEAST 10' FROM TOWN SEWER LINE
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD SEWERSPOOL OR PRIVY
 IS FROM central lawn
 IS COMPLETED WELL LOCATED AS SHOWN
 ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RESERVED
 DEC 31 1986
 WATER SUPPLY
 Rk 32-16

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	1
Geey Clay	1	4
Fine to med. shug. clay	4	22
Fine to med. Tan Sand	22	43
Fine to coarse white sand	43	67
Fine to coarse white sp/ly	67	99
Geey Clay	99	105

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF 1 PAGES
 COMPANY NAME AWIS
 SIGNATURE OF DRILLER IN CHARGE: Paul M. Curry Jr DATE 10/15/86