

MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG


Rh34-08

PAGE 1 OF 1 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT# 159099 w	LOCAL ID#	
PROPERTY OWNER Robert Timothy Geay Jr.		
WELL CONTRACTOR Somerset Well Drilling Co.-Inc	LIC# 4033	
DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Surface Soil	0	5
Sand	5	8
Brown Clay Q _{cs}	8	9
Tan Sand	9	21
Light Gray Clay + Sand Q _o	21	27
Blue Clay	27	41
Sand, Gravel w/wood	41	50
Sand, Gravel & Clay	50	75
Sand, Gravel T _{bd}	75	100 -
Alt: 30'		

OTHER COMMENTS: 4" X 100' with 10' screen #.010 slot size



I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller In Charge: Michael J Hall License# 4034 Date 07/02/98

White - DNREC • Canary - Contractor • Pink - Owner