

STATE OF DELAWARE  
 WATER AND AIR RESOURCES COMMISSION  
 Water Resources Division  
 Dover, Delaware 19901

WRD-2  
 7/69  
 WATER SUPPLY BRANCH

MAY 11 1977

WELL COMPLETION REPORT

1. Permit Number: 38290  
 Owner of Well: Quinty Corbett Co

2. Test Well  
 Observation Well       
 Production Well       
 Well Abandoned? Yes      No

3. Total Well Depth 55 feet  
 Date Completed 5-6-77

4. Grout: Type None  
 from      feet to      feet  
 from      feet to      feet

5. casing: Type 2" PVC  
0 inches to 55 feet  
     inches to      feet  
 Drive Shoe? Yes      No

6. Screen Setting:  
50 feet to 55 feet

7. Gravel Packed? Yes  No       
50 feet to 55 feet

8. Well Head Completion:  
 Pitless Adapter      Type       
8 inches above ~~grade~~

9. Static Water Level:  
9 feet below grade  
     feet above grade

10. Pumping Water Level:  
12 feet below grade after  
2 hours at 5 GPM

11. Permanent Pump Installed?  
 Yes      No   
 a. Shallow Well       
 Deep Well       
 b. Reciprocating      Rotary       
 Centrifugal      Jet       
 Submersible       
 c. Capacity      GPM

12. Well Number       
 (Leave Blank)

Ri21-09

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
fine brown sand	5'	5'
gray clay	10'	15'
fine brown sand w/ gravel	10'	25'
" " "	10'	35'
" gray "	10'	55'