



MAIL TO:

WATER SUPPLY SECTION  
DIVISION OF WATER RESOURCES  
89 KINGS HIGHWAY  
DOVER, DELAWARE 19901  
PHONE: 302-739-3665  
FAX: 302-739-2296

STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST  
BE RETURNED WITHIN 30 DAYS OF  
CONSTRUCTION DATE

FORMATION LOG

Rid 3-10

PAGE 2 OF 2 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT#	169905	LOCAL ID#	
PROPERTY OWNER	Artesian Water Co.		
WELL CONTRACTOR	A.C. Schultes of Maryland, Inc.	LIC#	221
DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA	
Topsoil	0-1		
Orange clay	1-4 Q <sub>2</sub>		
White and gray clay	4-18		
Fine to coarse white sand	18-31 T <sub>bd</sub>		
Medium to coarse orange sand	31-95		
Gray Clay	95-100 T <sub>bd</sub>		
Alt: 12'			

OTHER COMMENTS:

RECEIVED  
JAN 31 2000  
WATER SUPPLY

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

[Signature] License# 629 Date 1/25/00  
Signature of Well Driller In Charge