

76033 LOCAL 10

MR. LARSON

INSTALLATION DATE 10-17-88

TEST PERMANENT

DOMESTIC AGRICULTURAL
COMMERCIAL INDUSTRIAL
IRRIGATION PUBLIC
MONITOR DEWATERING
HEAT PUMP RECHARGE HEAT PUMP SUPPLY
OTHER (Specify)

REPLACEMENT WELL? YES NO

INSTALLMENT DATE FOR OLD WELL N/A
INSTALLMENT METHOD N/A

DRILLING METHOD
BORED CABLE TOOL
JETTED AIR ROTARY
REVERSE WASHED
DEPTH DRILLED 73

CASING SEQUENCE table with columns INNER, OUTER and rows for TOP, BOTTOM, DIAMETER, MATERIAL (SCH 40 PVC)

SCREEN SEQUENCE table with columns INNER, OUTER and rows for TOP, BOTTOM, DIAMETER, MATERIAL (SCH 40 PVC)

WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE AQUIFER MUST BE OBTAINED FROM DNRDC

TYPE: CEMENT BENTONITE CLAY

3 TO 35 FEET

OUTER BACKFILL OF WELL ANNULUS

STINGS FROM 35 TO 63 FEET

PACK: TYPE MGRIE 142

63 TO 73 FEET

WATER LEVEL DATE 10-17-88

FT. (Below, above) GROUND SURFACE

G WATER LEVEL: 11 FT. BELOW GRADE

2 HOURS AT 50 GPM

HEAD COMPLETION:
RITING ADAPTOR
CASING
INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE
RATED CAPACITY (GPM) N/A
PUMP INTAKE SETTING FT. BELOW GRADE

THE COMPLETED WELL IS?
76033
A. AT LEAST 15' FROM ANY FOUNDATION
B. AT LEAST 50' FROM ANY SEPTIC TANK
C. AT LEAST 10' FROM TOWN SEWER LINE
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)
SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS 100' FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

R: 24-12

OCT 25 1988 AH

DRILLERS LOG table with columns DESCRIPTION, TOP OF STRATA, BOTTOM OF STRATA and rows for topsoil, brown clay, lt brown med fm, gray clay, gray sd fm w/ clay, lt gray sd med, lined med

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF 1 PAGES
COMPANY NAME LARSON WELLS, INC.
SIGNATURE OF DRILLER IN CHARGE John Larson
DATE 10-24-88