

LOCAL ID  
 Marion Carter  
 PROTECTION DATE 8-9-88  
 TEST PERMANENT  
 DOMESTIC  
 COMMERCIAL  
 IRRIGATION  
 MONITOR  
 HEAT PUMP RECHARGE  
 OTHER (Specify)  
 REPLACEMENT WELL? YES  NO   
 INSTALLMENT DATE FOR OLD WELL  
 INSTALLMENT METHOD

DRILLING METHOD  
 BORED  JETTED  REVERSE   
 CABLE TOOL  AIR ROTARY  WASHED   
 OTHER (Specify)  
 DEPTH DRILLED 61

CASING SEQUENCE

	INNER	OUTER
TOP	14"	
BOTTOM	47'	
DIAMETER	4"	
MATERIAL	PC	

SCREEN SEQUENCE

	INNER	OUTER
TOP	47'	
BOTTOM	57'	
DIAMETER	4"	
MATERIAL	PC	

WRITTEN APPROVAL FOR SCREENING/  
 GRAVEL PACKING MORE THAN ONE AQUIFER  
 MUST BE OBTAINED FROM DNREC

TYPE: CEMENT  BENTONITE CLAY   
 0 TO 30 FEET  
 ROUT BACKFILL OF WELL ANNULUS  
 FROM TO FEET  
 PACK TYPE #2  
 35 TO 57 FEET  
 WATER LEVEL DATE 8-9-88  
 FT. (Below, above) GROUND SURFACE  
 G WATER LEVEL 0.6 FT. BELOW GRADE  
 1.5 HOURS AT 33.50 GPM.

HEAD COMPLETION:  
 PITLESS ADAPTOR   
 FEET ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:  
 PUMP MANUFACTURER Grundfos  
 RATED CAPACITY (GPM) 20  
 PUMP INTAKE SETTING 40 FT. BELOW GRADE  
 THE COMPLETED WELL IS?  
 YES NO  
 A. AT LEAST 15' FROM ANY FOUNDATION    
 B. AT LEAST 50' FROM ANY SEPTIC TANK    
 C. AT LEAST 10' FROM TOWN SEWER LINE    
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD    
 THE NEAREST NEIGHBORS (CIRCLE ONE)  
 SEPTIC TILE FIELD CESSPOOL OR PRIVY  
 IS 100' FROM COMPLETED WELL.  
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?    
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

R: 33-06  
 AUG 23 1988  
 WATER SUPPLY

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
top soil	0	1
f. tan sand w/clay	1	4
f. tan sand	4	11
White f/m sand	11	26
tan f/c w/gravel	26	61

SUPPLEMENTAL DRILLERS LOG ATTACHED YES  NO   
 PAGE 1 OF PAGES  
 COMPANY NAME  
 SIGNATURE OF DRILLER IN CHARGE  
 DATE 8/14/88