

MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG

R.31-24
Alt: 4

PAGE _____ OF _____ PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT# 18243	182043	LOCAL ID#			
PROPERTY OWNER Ray Weingartner					
WELL CONTRACTOR Somerset Well Drilling Co., Inc.	LIC# 4033				
DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA			
Surface Soil	0	5			
Yellow and white Clay	5	10			
Sand	10	30			
Yellow Clay	30	42			
Blue Clay	42	51			
Sand	51	60			
Hard Layer	60	61			
White Clay	61	66			
Blue Clay	66	72			
Sand	72	84			
Sand & Gravel	84	123			
Blue Clay	123	130			
Sand & Gravel w/ Clay	130	189			
Sand & Gravel	189	200			
OTHER COMMENTS: Set well 2' X 200 ft. with 15ft. #.010 slot screen.					
<table border="1"> <tr> <td>RECEIVED</td> </tr> <tr> <td>MAR 07 2002</td> </tr> <tr> <td>WATER SUPPLY</td> </tr> </table>			RECEIVED	MAR 07 2002	WATER SUPPLY
RECEIVED					
MAR 07 2002					
WATER SUPPLY					

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller In Charge *Michael J. Hall*

License# 4030

White - DNREC • Canary - Contractor • Pink - Owner

Date

11/12/01