

Local ID 14  
Revan View Townhouses

DATE 11/19/85  PERMANENT  
 TEST  
 DOMESTIC  AGRICULTURAL  
 COMMERCIAL  INDUSTRIAL  
 IRRIGATION  PUBLIC  
 MONITOR  DEWATERING  
 HEAT PUMP RECHARGE  HEAT PUMP SUPPLY  
 OTHER (Specify) \_\_\_\_\_  
 REPLACEMENT WELL? YES  NO   
 ADAPT DATE FOR OLD WELL N/A  
 ADAPT METHOD N/A

DRILLING METHOD  
 BORED  CABLE TOOL  
 JETTED  AIR ROTARY  
 REVERSE  WASHED  
 (Specify) \_\_\_\_\_  
 DEPTH DRILLED 380'

CASING SEQUENCE

DEPTH	INNER	COVER
2'		
350'		
4"		
	PVC	

SCREEN SEQUENCE

DEPTH	INNER	OUTER
350'		
380'		
4"		
	PVC	

NOTE: CEMENT  BENTONITE CLAY   
 WRITTEN APPROVAL FOR SCREENING/ GRAVEL PACKING MORE THAN ONE ANNU- LUS IFER MUST BE OBTAINED FROM DNREC.


TO 20 FEET  
 BACKFILL OF WELL ANNULUS  
 FROM \_\_\_\_\_ TO \_\_\_\_\_ FEET  
 CK: TYPE MURKIN #2  
 TO 300 FEET  
 PER LEVEL: DATE 11/19/85  
 (Below, above) GROUND SURFACE  
 FEET LEVEL: 17 FT. BELOW GRADE  
1/2 HOURS AT 35 GPM.

AD COMPLETION:  
 ADAPTOR   
 FEET ABOVE GRADE \_\_\_\_\_

TYPE OF PERMANENT PUMP INSTALLED  
Grundfos  
 PUMP MANUFACTURE  
 RATED CAPACITY (GPM) 30  
 PUMP INTAKE SETTING 40 FT. BELOW GRADE  
 THE COMPLETED WELL IS?

- A. AT LEAST 5' FROM ANY OVERHANG YES  NO   
 B. AT LEAST 50' FROM ANY SEPTIC TANK YES  NO   
 C. AT LEAST 10' FROM TOWN SEWER LINE YES  NO   
 D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES  NO

THE NEAREST NEIGHBORS (CIRCLE ONE)  
 SEPTIC TILE FIELD  CESSPOOL OR PRIVY  
 IS 100' FROM COMPLETED WELL.  
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?    
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



RJ 32-60

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
White clay	1	2
white/gray sand	2	18
gray yellow clay	18	46
white/blue clay	46	122
white/blue sand	122	155
clay	155	190
blue sand + clay	190	320
gray blue sand	320	341
gray blue clay	341	390

SUPPLEMENTAL DRILLERS LOG ATTACHED YES  NO   
 PAGE 1 OF \_\_\_\_\_ PAGES  
 COMPANY NAME WATER SUPPLY CO  
 SIGNATURE OF DRILLER IN CHARGE: Billy Conroy DATE 11/19/85