


# Delmarva Drilling Co., Inc.

P. O. BOX 188



DELAWARE 19933

094104

Water Well Contractors

CUSTOMER Seaford Elks Lodge STATE OF DELAWARE WATER RESOURCES SECTION JOB 2227  
 ADDRESS Rt. 46 Seaford, Delaware RECEIVED FEB 17 1975 DATE 11/15/74  
 LOCATION 65' W. of Building 68' E. of pond DELAWARE GEOLOGICAL SURVEY

FEET FROM GROUND SURFACE		WELL LOG
0 TO.....		
GROUND	0-1	top soil
53' TOTAL DEPTH - FT. 50' ← CASING → SCREEN 3'	1-11	tan sand fine to coarse
	11-37	fine to coarse & white sand white clay layers
	37-38	iron ore layers
	38-43	fine to coarse tan sand iron
	43-45	fine to coarse tan sand white ore layers
	45-61	fine to coarse tan sand clear
		T.D.W. 53'

045-01 PERMIT # 31892-A

WELL NO. <u>1</u>	DIAMETER OF WELL <u>4"</u>	DEPT. OF WELL <u>53'</u>
HRS. PUMPED <u>3</u>	SLOT SIZE <u>.016</u>	TYPE OF CASING <u>PVC</u>
CAPACITY G.P.M. <u>40</u>	DRILLING MACHINE NO. <u>D-5</u>	LENGTH OF CASING <u>50'</u>
STATIC LEVEL <u>6'</u>	DRILLER <u>Person</u>	DISTANCE TO TOP OF SCREEN <u>50'-53'</u>
PUMPING LEVEL <u>18'</u>	GRAVEL <u>2 morie</u>	TYPE SCREEN <u>PVC</u>
SPECIFIC CAPACITY <u>3</u>	BAGS OF CEMENT <u>8</u>	SIZE OF SCREEN <u>4"</u>
PUMPED WITH <u>pumper</u>	DATE WELL COMPLETED <u>11/15/74</u>	
DEPTH OF CEMENT GROUT <u>22'-0</u>	DRILLER'S HELPER <u>Warren</u>	<u>Pierson</u>
DEPTH GRAVEL PACKED <u>44'-53'</u>		WELL DRILLER SIGNATURE