

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 153123 LOCAL ID _____

OWNER TOWNSEEDS, INC

CONSTRUCTION DATE 11/15/83

PURPOSE TEST PERMANENT

USE DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED _____

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	31			
CASING BOTTOM	60			
CASING DIAMETER	16"			
CASING MATERIAL	PVC			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	60			
SCREEN BOTTOM	110			
SCREEN DIAMETER	16"			
SCREEN MATERIAL	PVC			

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE AQU-
IFER MUST BE OBTAINED FROM DNR/C

GROUT TYPE CEMENT BENTONITE CLAY

OTHER _____

FROM 0 TO 30 FEET

NON-GROUT BACKFILL OF WELL ANNULIUS

TYPE _____ FROM _____ TO _____ FEET

GRAVEL PACK TYPE ACQUA 112

FROM 30 TO 110 FEET

STATIC WATER LEVEL DATE 11/15/83 11-15-83

110 FT (Below/above) GROUND SURFACE

PUMPING WATER LEVEL 38 FT. BELOW GRADE

IR 8 HOURS AT 10.5 GPM

WELL HEAD COMPLETION: TYPE PITLESS ADAPTOR

OTHER _____

11 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE STANLEY

RATED CAPACITY (GPM) 1000

PUMP INTAKE SETTING 67 FT BELOW GRADE

THE COMPLETED WELL IS?

- | | | |
|--|-------------------------------------|--------------------------|
| | YES | NO |
| A. AT LEAST 5' FROM ANY OVERHANG | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| B. AT LEAST 50' FROM ANY SEPTIC TANK | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| C. AT LEAST 10' FROM TOWN SEWER LINE | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY
IS 1.500' FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS

Rec'd 4/23/84

0223-08

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	0	1
Fine sand w/clay	1	6
Fine to med brown sand	6	38
Iron ore	38	39
Fine to med brown sand	39	48
Med to coarse tan sand w/iron ore	48	56
Med to coarse tan sand	56	111

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 2 PAGES

COMPANY NAME Delmarva Drilling

SIGNATURE OF DRILLER IN CHARGE _____ DATE 4/17/84