1 Harry Coal
Sand Hill Road
1 mile East of
Georgetown, Del.

Of 34-1

376

WRD-2
7/68

RECEIVED
NOV 27 1968
STATE OF DELAWARE
WATER RESOURCES DIVISION

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

WELL COMPLETION REPORT

1. Permit Number: _____

2. Well Depth 81 ft.

   Date Completed Oct. 30-68

3. Grout: Type _____

   from ____ ft. to ____ ft.

4. Casing:

   2 in. to 77 ft.

   ____ in. to ____ ft.

   Drive shoe? Yes ___ No ✓

5. Screen:

   77 ft. to 81 ft.

6. Well Head Completion:

   ____ Pitless Adapter

   12 inches above grade

7. Static Water Level:

   10 feet below grade

8. Pumping Level:

   29 ft. after 2 hrs.

   at 22 GPM

9. Type of Permanent Pump:
   Installed by others
   Reciprocating ___ Jet ___

   Submersible ___ Other ___

   Capacity: _____ GPM

10. If well was electric or gamma logged submit copies of the log with this report.

11. Well Log

Formation	Thickness of Stratum	Depth to bottom of Stratum
top soil	6"	6"
grey sand soil	1½'	2'
clayey white and yellow sand	2	4
slightly clayey dirty fine white sand	13	17
very fine yellow sand and silt and sandy yellow and white clay	14	31
very fine to very coarse very dirty white sand and silt and very small gravel	28	59
fine to very coarse white and yellow sand (mostly medium coarse) and very small and small gravel	2	61
very fine to coarse (mostly fine) slightly yellow white sand	16	77
very fine to very coarse light yellow sand (mostly medium coarse) and small gravel	4	81

12. Well Number _____
    (leave blank)

13. Signature of Water Well Contractor

    Roy E. White

    Date Nov. 5, 1968

(over)