

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

OF 34-15

WELL COMPLETION REPORT

1. Permit Number: 36240
 Owner of Well: James Donaway

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 67 feet
 Date Completed 6-15-76

4. Grout: Type NO GR
 from feet to feet
 from feet to feet

5. Casing: Type 2" PVC
0 inches to 67 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
62 feet to 67 feet

7. Gravel Packed? Yes No
62 feet to 67 feet

8. Well Head Completion: Ratee Type
 inches above grade

9. Static Water Level:
6 feet below grade
 feet above grade

10. Pumping Water Level:
12 feet below grade after
2 hours at 40 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity 10 GPM

12. Well Number
 (Leave Blank)

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
fine sand + white clay	8'	8'
medium coarse white sand + some white clay	12'	20'
fine brown sand	10'	30'
medium white sand + some white clay	10'	40'
medium lite brown sand	10'	50'
medium coarse lite brown sand	18'	68'