DEMAGE DISPOSAL SYSTEM FOR

WPC-1

[illegible] W MUNSELL PROPERTY ADDRESS RT 5 Box 405

DATE: 12-20-76

[illegible] Route 261

[illegible] Well

Indicate the cross section of the tile field or seepage bed in this area.



OF54-10

WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

7/69

WATER SUPPLY BRANCH

WELL CONSTRUCTION REPORT

1. Permit Number: 37737
Owner of Well: Karl W. Munsell

2. Dept Well
Observation Well ___
Production Well ✓
Well Abandoned? Yes ___ No ✓

3. Total Well Depth 84 feet
Date Completed 2-28-77

4. Casing: Type NONE
from ___ feet to ___ feet
from ___ feet to ___ feet

5. Casing: Type Galv. steel
2 inches to 80 feet
___ inches to ___ feet
Drive Shoe? Yes ___ No ✓

6. Screen Setting:
[illegible] feet to 84 feet

7. Gravel Packed? Yes ✓ No
75 feet to 84 feet

8. Well Head Completion:
___ Pitless Adaptor ___ Type
12 inches above grade

9. Static Water Level:
10 feet below grade
___ feet above grade

10. Pumping Water Level:
22 feet below grade after
2 hours at 70 GPM

11. Permanent Pump Installed?
Yes ___ No ✓
a. Shallow Well ___
Deep Well ___
b. Reciprocating ___ Rotary ___
Centrifugal ___ Jet ___
Submersible ___
c. Capacity ___ GPM

12. Well Number
(Leave Blank)

Formation	Thickness of Stratum	Depth to Bottom of Stratum
[illegible]	6	6
[illegible]	6	7
[illegible]	5	6
[illegible]	3	9
[illegible]	7	16
[illegible]	28	44
[illegible]	4	48
[illegible]	10	58
[illegible]	11	69
[illegible]	7	76
[illegible]	11	87

[illegible] Well Contractor Date

[illegible] 3-7-77

Document 20-06/78/03/10

STATE OF DELAWARE

FILE SEPA