

MAIL TO:
 WATER SUPPLY BRANCH
 DIVISION OF WATER RESOURCES
 P.O. BOX 100
 DOVER, DELAWARE 19901

STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE RETURNED 21 DAYS AFTER
 CONSTRUCTION DATE

011103 WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 69339 LOCAL ID 101

OWNER Joe Block

CONSTRUCTION DATE 07-22-87

PURPOSE: TEST PERMANENT

- USE:
- DOMESTIC
 - COMMERCIAL
 - IRRIGATION
 - MONITOR
 - HEAT PUMP RECHARGE
 - OTHER (Specify):
 - AGRICULTURAL
 - INDUSTRIAL
 - PUBLIC
 - Dewatering
 - HEAT PUMP SUPPLY

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

- DRILLING METHOD
- AUGERED
 - BORED
 - CABLE TOOL
 - DRIVEN
 - JETTED
 - AIR ROTARY
 - MUD ROTARY
 - REVERSE
 - WASHED
 - OTHER (Specify):

TOTAL DEPTH DRILLED 90

CASING SEQUENCE

DEPTH	DIAMETER	MATERIAL
+		
30		
4		
		PVC

SCREEN SEQUENCE

DEPTH	DIAMETER	MATERIAL
30		
90		
4		
		PVC

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____

FROM 9 TO 20 FEET

NON-GROUT BACKFILL OF WELL ANNULUS
 TYPE GRAVEL FROM 20 TO 90 FEET

GRAVEL PACK TYPE Gravel
 FROM 20 TO 90 FEET

STATIC WATER LEVEL: DATE 7/2/87
22 FT. (Below Ground Surface)

PUMPING WATER LEVEL: 30 FT. BELOW GRADE
 AFTER 5 HOURS AT 100 GPM.

WELL HEAD COMPLETION:
 TYPE: FITLESS ADAPTOR
 OTHER 12 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____
 RATED CAPACITY (GPM) 7
 PUMP INTAKE SETTING _____ FT. BELOW GRADE


- THE COMPLETED WELL IS?
- A. AT LEAST 5' FROM ANY OVERHANG YES NO
 - B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
 - C. AT LEAST 10' FROM TOWN BOUNDARY YES NO
 - D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS **RECEIVED**
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
 IS _____ FROM COMPLETED WELL **OCT 6 1987**

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM? YES NO

IF NO, DESCRIBE LOCATION CHANGE **WATER SUPPLY**

House



DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Topsoil	0	1
Fine Tan Sand	1	5
Med/Fine Tan Sand	5	11
Fine Tan Sand	11	20
Coarse Sand	20	25
Med/Fine Tan Sand	25	30
Med/Fine Tan Sand	30	75
Coarse Sand	75	90

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME Ripstone Well Drilling Co.

SIGNATURE OF DRILLER/OWNER [Signature] DATE _____