

MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-3665
FAX: 302-739-2296

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG

PAGE _____ OF _____ PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT# 199958 LOCAL ID# 0811-10

PROPERTY OWNER DOT Sweeney

WELL CONTRACTOR DGS LIC# 999

DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Topsoil	0	8"
red-brown silty fine sand to silty clay	8"	5'
light yellow fine sand, silty	5	9'
red-brown silty clay	9	13'
light yellow fine-medium silty sand	13	18'
" " " " little silt	18	25'
tight; white fine sandy clay	25	36'
yellow gray fine sand and clay, trace md-ss	36	52'
" " medium-coarse sand, little silty	52	66'
white fine sandy clay	66	72'
yellow gray medium-coarse sand, 1' gravel @ 77'	72	84'
interbedded yellow-gray fine-medium sand and	84	103'
thin (1-6") red sandy clay		
" " " " " " a little finer	103	119'
tight; trace of clay on auger	119	123'
trilling exact; same as 103-119'	123	128'

OTHER COMMENTS:

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

Signature of Well Driller In Charge License# 586 Date 6/30/04