

- IRRIGATION
- DINTOR
- HEAT PUMP RECHARGE
- OTHER (Specify) \_\_\_\_\_
- PUBLIC
- DEWATERING
- HEAT PUMP SUPPLY

IS THIS A REPLACEMENT WELL? YES  NO

ABANDONMENT DATE FOR OLD WELL \_\_\_\_\_

ABANDONMENT METHOD \_\_\_\_\_

**DRILLING METHOD**

- AUGERED
- DRIVEN
- MUD ROTARY
- OTHER (Specify) \_\_\_\_\_
- BORED
- JETTED
- REVERSE
- CABLE TOOL
- AIR ROTARY
- WASHED

**CASING SEQUENCE**

CASING TOP	INNER	OUTER
+	2'	
-	15'	
	4"	
	PVC + Steel	

**SCREEN SEQUENCE**

SCREEN TOP	INNER	OUTER
-	15'	
-	25'	
	4"	
	PVC	

WRITTEN APPROVAL FOR SCREENING/  
GRAVEL PACKING MORE THAN ONE AGU-  
FEM MUST BE OBTAINED FROM DNRDC.

GROUT TYPE: CEMENT  BENTONITE CLAY

OTHER: \_\_\_\_\_

FROM 0 TO 12 FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE \_\_\_\_\_ FROM \_\_\_\_\_ TO \_\_\_\_\_ FEET

GRAVEL PACK TYPE # 2 Well Gravel

FROM 12 TO 28 FEET

STATIC WATER LEVEL DATE 4.11.89

17' FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 25 FT. BELOW GRADE

AFTER \_\_\_\_\_ HOURS AT \_\_\_\_\_ GPM.

**WELL HEAD COMPLETION:**

TYPE: PITLESS ADAPTOR

OTHER  4" Locking Cap + Cover

24 INCHES ABOVE GRADE

C. AT LEAST 10' FROM TOWN SEWER LINE

D. AT LEAST 100' FROM THE NEAREST EDGE

OF ANY TILE FIELD

**THE NEAREST NEIGHBORS (CIRCLE ONE)**

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS 114 FROM COMPLETED WELL

IS COMPLETED WELL LOCATED AS SHOWN

ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

09/12-05

**DRILLERS LOG DESCRIPTION**

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	1
Thin Sandy Clay	1	4.5
8 in Fine to med. grit	4.5	10
Thin Silty Clay	10	15
Fine White Sand	15	28

SUPPLEMENTAL DRILLERS LOG ATTACHED YES  NO

PAGE 1 OF \_\_\_\_\_ PAGES

COMPANY NAME Enrich Data Inc.

SIGNATURE [Signature] DATE 5/19/89

75717

09/12-05