

WELL COMPLETION REPORT

09/2-08

✓

USE PRINT

PERMIT NO. 61240 LOCAL ID MW#22  
Draper Canning Co.

INSTRUCTION DATE 6-25-85  
PURPOSE:  TEST  PERMANENT

- DOMESTIC  AGRICULTURAL
- COMMERCIAL  INDUSTRIAL
- IRRIGATION  PUBLIC
- MONITOR  DEWATERING
- HEAT PUMP RECHARGE  HEAT PUMP SUPPLY
- OTHER (Specify) \_\_\_\_\_

IS THIS A REPLACEMENT WELL? YES  NO   
ABANDONMENT DATE FOR OLD WELL \_\_\_\_\_  
ABANDONMENT METHOD \_\_\_\_\_

DRILLING METHOD

- AUGERED  BORED  CABLE TOOL
- DRIVEN  JETTED  AIR ROTARY
- MUD ROTARY  REVERSE  WASHED
- OTHER (Specify) \_\_\_\_\_

TOTAL DEPTH DRILLED 28

CASING SEQUENCE

1st	2nd	3rd	4th
+ 1.5	2.5	25.0	
2.5	15.0	27.33	
4"	4"	4"	
steel	PVC	PVC	

SCREEN SEQUENCE

1st	2nd	3rd	4th
15.0			
25.0			
4"			
PVC			

WRITTEN APPROVAL FOR UNNO/ GRAVEL PACKING MORE THAN 10' AQUIFER MUST BE OBTAINED FROM AGC.

ROUT TYPE: CEMENT  BENTONITE CLAY   
 OTHER: \_\_\_\_\_  
 FROM 0 TO 13.0 FEET  
 NON-GROUT BACKFILL OF WELL ANNULUS  
 (PE) \_\_\_\_\_ FROM \_\_\_\_\_ TO \_\_\_\_\_ FEET  
 GRAVEL PACK: TYPE Jessie Maria #2  
 FROM 13.0 TO 27.33 FEET  
 STATIC WATER LEVEL: DATE \_\_\_\_\_  
 \_\_\_\_\_ FT. (Below, above) GROUND SURFACE  
 PUMPING WATER LEVEL: \_\_\_\_\_ FT. BELOW GRADE  
 AFTER \_\_\_\_\_ HOURS AT \_\_\_\_\_ GPM.

WELL HEAD COMPLETION:  
 TYPE: PITLESS ADAPTOR   
 OTHER  Locking Cap  
18 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE N/A  
 RATED CAPACITY (GPM) \_\_\_\_\_  
 PUMP INTAKE SETTING \_\_\_\_\_ FT. BELOW GRADE  
 THE COMPLETED WELL IS?

- |                                                          | YES                                 | NO                       |
|----------------------------------------------------------|-------------------------------------|--------------------------|
| A. AT LEAST 5' FROM ANY OVERHANG                         | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| B. AT LEAST 60' FROM ANY SEPTIC TANK                     | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| C. AT LEAST 10' FROM TOWN SEWER LINE                     | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY IS 100+ FROM COMPLETED WELL.  
 IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?    
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

See Draper Canning File

RECEIVED

AUG 27 1985

WATER SUPPLY

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRAT
Pr. Sandy Clay	0	1
White Sandy Clay	1	6
Gr/Bk. Sandy Clay	6	13
White Sand	13	20
Brown Sand	20	25
White Sand	25	27

SUPPLEMENTAL DRILLERS LOG ATTACHED YES  NO

PAGE 1 OF \_\_\_\_\_ PAGES

COMPANY NAME Earth Data Incorporated

SIGNATURE OF DRILLER IN CHARGE: Teed Mansfield DATE 8-20-85