

MAIL TO:

WATER SUPPLY BRANCH  
DIVISION OF ENVIRONMENTAL CONTROL  
P.O. BOX 1401  
DOVER, DELAWARE 19903

STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST  
BE RETURNED 30 DAYS AFTER  
CONSTRUCTION DATE

0915-06

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 93541 LOCAL ID \_\_\_\_\_

OWNER Draper Canning Co.

CONSTRUCTION DATE 12-10-92

PURPOSE:  TEST  PERMANENT

USE:  DOMESTIC  AGRICULTURAL  
 COMMERCIAL  INDUSTRIAL  
 IRRIGATION  PUBLIC  
 OBSERVATION  DEWATERING  
 HEAT PUMP RECHARGE  HEAT PUMP SUPPLY  
 OTHER (Specify) \_\_\_\_\_

IS THIS A REPLACEMENT WELL? YES  NO

ABANDONMENT DATE FOR OLD WELL \_\_\_\_\_

ABANDONMENT METHOD \_\_\_\_\_

DRILLING METHOD

AUGERED  BORED  CABLE TOOL  
 DRIVEN  JETTED  AIR ROTARY  
 MUD ROTARY  REVERSE  WASHED  
 OTHER (Specify) \_\_\_\_\_

TOTAL DEPTH DRILLED 97

CASING SEQUENCE

CASING TOP  
CASING BOTTOM  
CASING DIAMETER  
CASING MATERIAL

INNER	OUTER
<u>1 1/2</u>	
<u>7 7/8</u>	
<u>2</u>	
<u>PVC</u>	

SCREEN SEQUENCE

SCREEN TOP  
SCREEN BOTTOM  
SCREEN DIAMETER  
SCREEN MATERIAL

INNER	OUTER
<u>7 7/8</u>	
<u>9 7/8</u>	
<u>2</u>	
<u>PVC</u>	

WRITTEN APPROVAL FOR SCREENING/  
GRAVEL PACKING MORE THAN ONE AQU-  
IFER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT  BENTONITE CLAY

OTHER: \_\_\_\_\_

FROM \_\_\_\_\_ TO \_\_\_\_\_ FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE Nature FROM 0 TO 70 FEET

GRAVEL PACK: TYPE Morie #1

FROM 70 TO 97 FEET

STATIC WATER LEVEL: DATE 12-10-92

15 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 25 FT. BELOW GRADE

AFTER 2 HOURS AT 7.5 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER

12 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE N.A.

RATED CAPACITY (GPM) \_\_\_\_\_

PUMP INTAKE SETTING \_\_\_\_\_ FT. BELOW GRADE

THE COMPLETED WELL IS?

YES NO  
A. AT LEAST 15' FROM ANY FOUNDATION    
B. AT LEAST 50' FROM ANY SEPTIC TANK    
C. AT LEAST 10' FROM TOWN SEWER LINE    
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC, TILE FIELD CESSPOOL OR PRIVY

IS 100 FT FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN

ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

Q.P.S.

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
<u>topsoil</u>	<u>0</u>	<u>1</u>
<u>Silty tan sand</u>	<u>1</u>	<u>4</u>
<u>silty white sand</u>	<u>4</u>	<u>22</u>
<u>fine &amp; coarse white sand &amp; some silt</u>	<u>22</u>	<u>50</u>
<u>fine &amp; coarse light yellow sand</u>	<u>50</u>	<u>63</u>
<u>fine to very coarse dark yellow sand</u>	<u>63</u>	<u>67</u>
<u>fine to very coarse white sand, some small gravel</u>	<u>67</u>	<u>97</u>

SUPPLEMENTAL DRILLERS LOG ATTACHED YES  NO

PAGE 1 OF 1 PAGES

COMPANY NAME White Drilling Corp.

SIGNATURE OF DRILLER IN CHARGE: Roy E. White Jr DATE 12-10-92