

BE SUBMITTED
ED BEFORE
ED THIS
PROVED.
LL PERMIT



READY AND SAFE

PERMIT NO. 29754 E

ON IS HEREBY
ECT TO THOSE
XSTRUCTION

WELL CONTRACTOR

**STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL**

0023-09
WELL COMPLETION REPORT MUST
BE RETURNED 21 DAYS AFTER
CONSTRUCTION DATE
MA

WELL COMPLETION REPORT

MAIL TO:
WATER SUPPLY BRANCH
DIVISION OF ENVIRONMENTAL CONTROL
P.O. BOX 1407
DOVER, DELAWARE 19901

PLEASE PRINT

PERMIT NO. 59754 E LOCAL ID _____

OWNER Clifford Joseph

CONSTRUCTION DATE 1/24/85

PURPOSE TEST PERMANENT

USE DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 MONITOR DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL 1/24/85

ABANDONMENT METHOD CEMENT

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 66'

CASING SEQUENCE

	1st	2nd	3rd	4th
CASING TOP	8'			
CASING BOTTOM	66'			
CASING DIAMETER	8"			
CASING MATERIAL	PEL			

SCREEN SEQUENCE

	1st	2nd	3rd	4th
SCREEN TOP	66'			
SCREEN BOTTOM	66'			
SCREEN DIAMETER	8"			
SCREEN MATERIAL	PEL			

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE AMP-
PER MUST BE OBTAINED FROM DNR/EC

GROUT TYPE CEMENT BENTONITE CLAY

OTHER _____

FROM _____ TO _____ FEET

NON-GROUT BACKFILL OF WELL ANNULUS
TYPE NATIVE FROM 0 TO 66 FEET

GRAVEL PACK TYPE 2 FROM 66 TO 66 FEET

STATIC WATER LEVEL DATE 1/24/85

20 FT (below/above) GROUND SURFACE

PUMPING WATER LEVEL 23 FT. BELOW GRADE

AFTER 2 HOURS AT 60 GPM

WELL HEAD COMPLETION:

TYPE PITLESS ADAPTOR

OTHER

8 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE _____

RATED CAPACITY (GPM) _____

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

YES NO

A AT LEAST 5' FROM ANY OVERHANG

B AT LEAST 50' FROM ANY SEPTIC TANK

C AT LEAST 10' FROM TOWN SEWER LINE

D AT LEAST 100' FROM THE NEAREST EDGE OF ANY FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)

SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS 10' FROM COMPLETED WELL

IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?

IF NO DESCRIBE LOCATION CHANGE OR OTHER COMMENTS _____

RECEIVED
FEB 14 1985
WATER SUPPLY

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top soil	6	6'
SILTY TAN SAND	2-6"	3'
VERY FINE TO COARSE TAN SAND	3	6
SILTY YELLOW CLAY	5	11
CLAYEY YELLOW SAND	7	18
VERY FINE TO COARSE WHITE SAND	13	31
YELLOW SILTY SAND	17	50
FINE COARSE YELLOW SAND	18	68

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO

PAGE 1 OF 1 PAGES

COMPANY NAME White Drilling Corp.

SIGNATURE OF DRILLER IN CHARGE D. Allen White Sr. DATE 1/24/85

DOCUMENT NO. 20-06-78-01-02

WRITE - DNR/EC CANARY - CONTRACTOR PINK - OWNER

Document 20-06/78/05/10