

MAIL TO:
 WATER SUPPLY BRANCH
 DIVISION OF ENVIRONMENTAL CONTROL
 P.O. BOX 1401
 DOVER, DELAWARE 19903

STATE OF DELAWARE
 DEPARTMENT OF NATURAL RESOURCES
 AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
 BE RETURNED 30 DAYS AFTER
 CONSTRUCTION DATE

WELL COMPLETION REPORT

PLEASE PRINT

PERMIT NO. 110 956 LOCAL ID _____

OWNER Wilmer Hunter
Greenville De

CONSTRUCTION DATE 4-1-97
 PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 OBSERVATION DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO
 ABANDONMENT DATE FOR OLD WELL _____
 ABANDONMENT METHOD _____

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 60

CASING SEQUENCE

	INNER	OUTER
CASING TOP	+1	
CASING BOTTOM	50	
CASING DIAMETER	2	
CASING MATERIAL	PVC	

SCREEN SEQUENCE

	INNER	OUTER
SCREEN TOP	50	
SCREEN BOTTOM	60	
SCREEN DIAMETER	2	
SCREEN MATERIAL	PVC	

WRITTEN APPROVAL FOR SCREENING/
 GRAVEL PACKING MORE THAN ONE AQU-
 IFER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY
 OTHER: _____

FROM 0 TO 50 FEET

NON-GROUT BACKFILL OF WELL ANNULUS
 TYPE none FROM _____ TO _____ FEET

GRAVEL PACK: TYPE grit
 FROM 50 TO 60 FEET

STATIC WATER LEVEL: DATE 4-1-97

6 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 40 FT. BELOW GRADE

AFTER 2 HOURS AT 20 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR
 OTHER _____
12 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:


PUMP MANUFACTURE _____
 RATED CAPACITY (GPM) _____
 PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

	YES	NO
A. AT LEAST 15' FROM ANY FOUNDATION	<input checked="" type="checkbox"/>	<input type="checkbox"/>
B. AT LEAST 50' FROM ANY SEPTIC TANK	<input type="checkbox"/>	<input type="checkbox"/>
C. AT LEAST 10' FROM TOWN SEWER LINE	<input type="checkbox"/>	<input type="checkbox"/>
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD	<input type="checkbox"/>	<input type="checkbox"/>

THE NEAREST NEIGHBORS (CIRCLE ONE)

TILE FIELD CESSPOOL OR PRIVY
 IS 100 FROM COMPLETED WELL.
 IS COMPLETED WELL LOCATED AS SHOWN
 ON APPLICATION FORM?
 IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



RECEIVED
 APR 17 1997
 WATER SUPPLY

DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
Top Soil	0	2
Tan Sand	2	6
Tan Clay	6	9
Coarse Tan Sand	9	30
Dark Tan Sand	30	40
Coarse Tan Sand	40	60

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
 PAGE 1 OF _____ PAGES
 COMPANY NAME Lifetime Well Drilling
 SIGNATURE OF DRILLER IN CHARGE: Ben Wood DATE 4/18/97