

WELL COMPLETION REPORT

0945-00

1. Permit Number: 36928
 Owner of Well: Rodger J Clavette

8. Well Head Completion:
 _____ Fittless Adapter _____ Type
 _____ inches above grade

2. Test Well _____
 Observation Well _____
 Production Well X
 Well Abandoned? Yes _____ No X

9. Static Water Level:
11 feet below grade
 _____ feet above grade

3. Total Well Depth 166 feet
 Date Completed 9/1/76

10. Pumping Water Level:
15 feet below grade after
1 hours at 70 GPM

4. Grout: Type _____
 from _____ feet to _____ feet
 from _____ feet to _____ feet

11. Permanent Pump Installed?
 Yes _____ No X
 a. Shallow Well _____
 Deep Well _____
 b. Reciprocating _____ Rotary _____
 Centrifugal _____ Jet _____
 Submersible _____
 c. Capacity _____ GPM

5. Casing: Type PVC
2 inches to 66 feet
 _____ inches to _____ feet
 Drive Shoe? Yes _____ No X

12. Well Number _____
 (Leave Blank)

6. Screen Setting:
56 feet to 66 feet

7. Gravel Packed? Yes X No _____
56 feet to 66 feet

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
med coarse brown sand	10	10
coarse white sand	10	20
yellow clay	10	30
fine brown sand w/ clay	10	40
med coarse white sand	10	50
coarse white sand	16	66

14. Signature of Water Well Contractor W.D. H. Burns

Date 9/23/76