

0951-03

1. Permit Number: 37142
 Owner of Well: RONALD W. MOORE

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No X

3. Total Well Depth 73 feet
 Date Completed 9/29/76

4. Grout: Type PCC Cement
 from 0 foot to 63 feet
 from feet to feet
20' JOINTS

5. Casing: Type PVC SH 240
0 inches to 63 feet
 inches to feet
 Drive Shoe? Yes No X

6. Screen Setting:
73 feet to 63 feet

7. Gravel Packed? Yes X No
74 feet to 63 feet

3. Well Head Completion: SANITARY Se
1 Pitless Adapter #352 SEAT
22 inches above grade
below

9. Static Water Level:
16 feet below grade
 feet above grade

10. Pumping Water Level:
16 feet below grade after
15 hours at 25 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

13. Well Log

Perforation	Thickness of Stratum	Depth to Bottom of Stratum
TOP SOIL	0" - 2'	
CLAY WITH GRAVEL	2' - 8'	
GRAVEL	8' - 5'	
SAND	15' - 30'	
WATER VEIN + GRAVEL	30' - 35'	
SAND	35' - 68'	
GRAVEL, COARSE SAND + WATER VEIN	68' - 74'	

14. Signature of Well Contractor Date