

Water Resources Division
 Dover, Delaware 19901

WATER SUPPLY BRANCH
 JAN 6 1977

0054-01

WELL COMPLETION REPORT

1. Permit Number: 37416
 Owner of Well: Walter O. Hunky

2. Test Well: —
 Observation Well: —
 Production Well: —
 Well Abandoned? Yes — No X

3. Total Well Depth: RR feet
 Date Completed: Dec. 22, 1976

4. Grout: Type NAH
 from — feet to — feet
 from — feet to — feet

5. Casing: Type Galv. steel
2 inches to 21 feet
— inches to — feet
 Drive Shoe? Yes — No X

6. Screen Settings:
81 feet to 85 feet

7. Gravel Packed? Yes X No —
7.5 feet to 85 feet

8. Well Head Completion:
 Pitless Adapter: — Type —
12 inches above grade

9. Static Water Level:
3 feet below grade
— feet above grade

10. Pumping Water Level:
24 feet below grade after
2 hours at 60 GPM

11. Permanent Pump Installed?
 Yes — No X
 a. Shallow Well —
 Boop Well —
 b. Reciprocating — Rotary —
 Centrifugal — Jet —
 Submersible —
 c. Capacity — GPM

12. Well Lumber
 (Leave Blank)

13. Well Log

| Formation | Thickness of Stratum | Depth to Bottom of Stratum |
|---|----------------------|----------------------------|
| fine light yellow sand | 6 | 6 |
| fine sandstone with light yellow sand | 13 | 19 |
| medium sandstone with light yellow sand | 13 | 32 |
| medium sandstone with light yellow sand | 7 | 39 |
| medium sandstone with light yellow sand | 11 | 50 |
| medium sandstone with light yellow sand | 6 | 56 |
| medium sandstone with light yellow sand | 16 | 72 |
| medium sandstone with light yellow sand | 9 | 81 |
| medium sandstone with light yellow sand | 8 | 89 |
| medium sandstone with light yellow sand | 8 | 97 |
| medium sandstone with light yellow sand | 8 | 105 |

Document 20-06/78/05/10