

*Rec'd  
8/5/68  
Mr. C. ...*

# DELMARVA DRILLING CO. INC. Pb 35-2

BOX 456, DENTON, MARYLAND PHONE (301) 454-1678

## WELL DRILLING & PUMPS

**P095-2**

DATE 12/6/66

Pb 35-2

CUSTOMER Ralph O'Day 17" 43 NO. HOLES  
 ADDRESS Seaford, Delaware States & District  
 LOCATION 20' east of Route 3 and 50' S.W. of 1" well

START	STOP	FORMATION
0	2'	Perm
2'	3	Topsoil
3	15	Fine-coarse brown sand w/gravel and clay layers (small)
15	18	" " tan sand w/gravel
18	27	" " light tan sand
27	31	" " " " " w/gravel
31	41	" " " " " w/gravel and stone & rock
41	50	Med.-coarse tan sand
50	63	Mostly coarse light tan sand
63	64	" " " " " w/small gray clay layers
64	70	Gray clay
70	90	Mostly med.-coarse tan sand
90	91	Blue clay

CASING & SCREEN RECORD:		
Plain	0-33	61-69
Screen	33-37	69-73
Plain	37-41	73-77
Screen	41-45	77-81
Plain	45-49	81-85
Screen	49-53	85-89
Plain	53-57	
Screen	57-61	
Clay Seal		
Gravel Pack	0 - 89	

Static Water Level 20 Feet  
 G. P. M. Pumped 919  
 Water Level While Pumping 42 Feet  
 # Bays of Clay Used \_\_\_\_\_  
 Type Gravel Pack Used Rosser Pea  
 Approx. Gal. Water Used To Drill \_\_\_\_\_  
 Guarantee With Turbine from Test \_\_\_\_\_ G. P. M.  
 Water Appearance (Clear, Clayey, Sandy, Odor, Taste) \_\_\_\_\_

REMARKS: Spacer blocks 31', 59', and 87'