

MAIL TO:

WATER SUPPLY SECTION
DIVISION OF WATER RESOURCES
89 KINGS HIGHWAY
DOVER, DELAWARE 19901
PHONE: 302-739-9944
FAX: 302-739-7764

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED WITHIN 30 DAYS OF
CONSTRUCTION DATE

FORMATION LOG


PAGE 1 OF 1 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT#	214323		LOCAL ID#	PB 44-03	
PROPERTY OWNER	DOT Sussex				
WELL CONTRACTOR	DGS			LIC#	999
	DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA		
	Sand, medium to fine, well sorted with coarse laminae, lt yellowish brown	0	7		
	Interbedded silt, organic rich and fine to coarse sand, lt brownish gray	7	13		
	Clay, silty, stiff, dark gray	13	20		
	Sand, beds of mc-gran grading up to very fine to fine, pale yellow	20	37		
	Sand, coarse to medium, gray	37	77		
	Sand, silty, f-medium, gray	77	88		
	Clay, silty, gray to olive gray, some f-vf sandy zones 103-112	88	118		
	Sand, f-m, gray	118	124		
	Clay, silty, gray, tight drilling	124	133		

OTHER COMMENTS:

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT


686
5/15/06
 Signature of Well Driller In Charge License# Date