

Water Well Contractors

CUSTOMER E. I. duPont Co.

Job 3184

ADDRESS Seaford, Delaware

DATE 6/24/76

LOCATION 3100' W. of river 60' E. of Rt. 536

GROUND	FEET FROM GROUND SURFACE		WELL LOG
	0 TO.....		
	0-1	2'	top soil
	1-5		fine to med. brown sand
	5-10		med. to coarse brown sand with stones
	10-35		fine to med. white sand
	35-40		fine to med. white sand with clay layers
	40-60		fine to med. white sand
	60-80		tan sand med. to coarse
	80-94		coarse tan to med. sand tan
	94-100		gray clay

Permit # 25641

WELL NO. <u>22A</u>	DIAMETER OF WELL <u>2"</u>	DEPT. OF WELL <u>80'</u>
MRS. PUMPED <u>1</u>	SLOT SIZE <u>.016</u>	TYPE OF CASING <u>2 steel</u>
CAPACITY G.P.M. <u>6</u>	DRILLING MACHINE NO. <u>D-1</u>	LENGTH OF CASING <u>75'</u>
STATIC LEVEL <u>22'4"</u>	DRILLER <u>H. Masten</u>	DISTANCE TO TOP OF SCREEN <u>75-80'</u>
PUMPING LEVEL <u>25'</u>	GRAVEL <u>#2</u>	TYPE SCREEN <u>8.8.</u>
SPECIFIC CAPACITY <u>2</u>	BAGS OF CEMENT <u>9</u>	SIZE OF SCREEN <u>2"</u>
PUMPED WITH <u>air pumper</u>	DATE WELL COMPLETED <u>6/24/76</u>	
DEPTH OF CEMENT GROUT <u>0-70</u>	DRILLER'S HELPER <u>J. Sori</u>	<u>H. Masten</u>
DEPTH GRAVEL PACKED <u>70-80</u>		

WELL DRILLER SIGNATURE