

WELL COMPLETION REPORT

1. Permit Number: 36242  
 Owner of Well: C. A. White

2. Test Well  
 Observation Well —  
 Production Well —  
 Well Abandoned? Yes — No ✓

3. Total Well Depth 107 feet  
 Date Completed 6-9-26

4. Grout: Type NONE  
 from — feet to — feet  
 from — feet to — feet

5. Casing: Type 2" CPVC  
2 inches to 107 feet  
— inches to — feet  
 Drive Shoe? Yes — No ✓

6. Screen Setting:  
102 feet to 107 feet

7. Gravel Packed? Yes ✓ No —  
102 feet to 107 feet

13. Well Log

8. Well Head Completion:  
NONE Adapter — Type —  
2 inches above grade

9. Static Water Level:  
3 feet below grade  
— feet above grade

10. Pumping Water Level:  
2 feet below grade after  
2 hours at 60 GPM

11. Permanent Pump Installed?  
 Yes — No ✓  
 a. Shallow Well —  
 Deep Well —  
 b. Reciprocating — Rotary —  
 Centrifugal — Jet —  
 Submersible —  
 c. Capacity — GPM

12. Well Number —  
 (Leave Blank)

P 35-10

Formation	Thickness of Stratum	Depth to Bottom of Stratum
<u>Medium coarse white sand</u>	<u>20'</u>	<u>20'</u>
<u>fine red sand</u>	<u>10'</u>	<u>30'</u>
<u>light gray clay</u>	<u>50'</u>	<u>80'</u>
<u>fine red sand &amp; red clay</u>	<u>10'</u>	<u>90'</u>
<u>medium coarse red sand</u>	<u>10'</u>	<u>100'</u>
<u>coarse yellow sand</u>	<u>7'</u>	<u>107'</u>

14. Signature of Water Well Contractor W. H. Burns Date June 10, 1926