

WELL COMPLETION REPORT

1. Permit Number: 36243  
 Owner of Well: C.O. White  
Robert Eugene Property

2. Test Well  
 Observation Well       
 Production Well   ✓    
 Well Abandoned? Yes      No   ✓  

3. Total Well Depth 102 feet  
 Date Completed 6-9-76

4. Grout: Type ALOCIE  
 from      feet to      feet  
 from      feet to      feet

5. Casing: Type 2" PVC  
0 inches to 102 feet  
     inches to      feet  
 Drive Shoe? Yes      No   ✓  

6. Screen Setting:  
97 feet to 102 feet

7. Gravel Packed? Yes   ✓   No       
97 feet to 102 feet

8. Well Head Completion:  
NO Adapter      Type       
8 inches above grade

9. Static Water Level:  
3 feet below grade  
     feet above grade

10. Pumping Water Level:  
6 feet below grade after  
2 hours at 70 GPM

11. Permanent Pump Installed?  
 Yes      No   ✓    
 a. Shallow Well       
    Deep Well       
 b. Reciprocating      Rotary       
    Centrifugal      Jet       
    Submersible       
 c. Capacity      GPM

12. Well Number       
 (Leave Blank)

PC35-11.

13. Well Log

Formation	Thickness of Stratum	Depth to Bottom of Stratum
Medium coarse white sand	10'	10'
fine red sand	20'	30'
light gray sand	55'	85'
fine gray sand	5'	90'
coarse yellow sand	12'	102'

14. Signature of Water Well Contractor W.H. Burns Date June 10, 1976