

PC 45-3

TELEPHONE 302/337-8254

Dubois

Delmarva Drilling Co., Inc.

RECEIVED

P. O. BOX 188

BRIDGEVILLE, DELAWARE 19933
SEP 30 1977

LAO

DELAWARE GEOLOGIC Water Well Contractors

SURVEY Permit # 38221

CUSTOMER B & B Traylor Court No. 2 JOB 3832
 ADDRESS Seaford, Del. DATE 7/14/77
 LOCATION 25' N. of Blacktop Rd. & 15' S.W. of traylor

GROUND	FEET FROM GROUND SURFACE 0 TO.....	WELL LOG
	1-4	tan fine sand
	4-14	white fine sand & clay
	14-16	white med sand
	16-42	tan fine to coarse sand
	42-103	tan fine to med sand
	103-106	yellow & white clay
	106-123	tan finetomed sand
	123-148	gray clay fine sand
	148-254	gray clay w/ shell
	254-261	fine gray sand w/ shell
	261-284	fine gray sand w/ shell <i>summed</i>
	284-325	shell & green clay & fine sand
	325-327	hard layer
	327-334	shell & clay green
	334-342	brown clay & fine sand
	342-356	shell & fine sand & clay
	356-359	fine sand & clay & shell
	359-393	shell very hard & brown clay

TOTAL DEPTH - FT. *280*



WELL NO. <u>1</u>	DIAMETER OF WELL <u>4"</u>	DEPT. OF WELL <u>280'</u>
HRS. PUMPED <u>24</u>	SLOT SIZE <u>.016</u>	TYPE OF CASING <u>PVC</u>
CAPACITY G.P.M. <u>4</u>	DRILLING MACHINE NO. <u>D-1</u>	LENGTH OF CASING <u>260</u>
STATIC LEVEL <u>21'</u>	DRILLER <u>C. Wallace-G. Pierson</u>	DEPTH TO TOP OF SCREEN <u>260-280</u>
PUMPING LEVEL <u>23</u>	GRAVEL <u>1-2</u>	TYPE SCREEN <u>PK PVC</u>
SPECIFIC CAPACITY <u>2</u>	BAGS OF CEMENT <u>2</u>	SIZE OF SCREEN <u>4"</u>
PUMPED WITH <u>pump</u>	DATE WELL COMPLETED <u>7/18/77</u>	
DEPTH OF CEMENT <u>0-20</u>	DRILLER'S HELPER <u>Ken Custer</u>	<u>C. Wallace-G. Pierson</u> WELL DRILLER SIGNATURE
DEPTH GRAVEL PACKED <u>230-393</u>	<u>H. Tpler</u>	