

MAIL TO:

WATER SUPPLY BRANCH
DIVISION OF ENVIRONMENTAL CONTROL
P.O. BOX 1401
DOVER, DELAWARE 19903

STATE OF DELAWARE
DEPARTMENT OF NATURAL RESOURCES
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST
BE RETURNED 30 DAYS AFTER
CONSTRUCTION DATE

WELL COMPLETION REPORT

LEASE PRINT

PERMIT NO. 77822 LOCAL ID 101

OWNER NICHOLAS NICOLETAS
612 Ridge Rd., Lynhurst N.J.

CONSTRUCTION DATE 3-2289

PURPOSE: TEST PERMANENT

USE: DOMESTIC AGRICULTURAL
 COMMERCIAL INDUSTRIAL
 IRRIGATION PUBLIC
 OBSERVATION DEWATERING
 HEAT PUMP RECHARGE HEAT PUMP SUPPLY
 OTHER (Specify) _____

IS THIS A REPLACEMENT WELL? YES NO

ABANDONMENT DATE FOR OLD WELL _____

ABANDONMENT METHOD _____

DRILLING METHOD

AUGERED BORED CABLE TOOL
 DRIVEN JETTED AIR ROTARY
 MUD ROTARY REVERSE WASHED
 OTHER (Specify) _____

TOTAL DEPTH DRILLED 55

CASING SEQUENCE

CASING TOP
CASING BOTTOM
CASING DIAMETER
CASING MATERIAL

	INNER	OUTER
CASING TOP	+1	
CASING BOTTOM	47	
CASING DIAMETER	2	
CASING MATERIAL	PVC	

SCREEN SEQUENCE

SCREEN TOP
SCREEN BOTTOM
SCREEN DIAMETER
SCREEN MATERIAL

	INNER	OUTER
SCREEN TOP	47	
SCREEN BOTTOM	55	
SCREEN DIAMETER	2	
SCREEN MATERIAL	PVC	

WRITTEN APPROVAL FOR SCREENING/
GRAVEL PACKING MORE THAN ONE AQU-
IFER MUST BE OBTAINED FROM DNREC.

GROUT TYPE: CEMENT BENTONITE CLAY

OTHER: _____

FROM 3 TO 20 FEET

NON-GROUT BACKFILL OF WELL ANNULUS

TYPE SAND/CLAY FROM 20 TO 55 FEET

GRAVEL PACK: TYPE _____ GRIT _____

FROM 20 TO 55 FEET

STATIC WATER LEVEL: DATE _____

12 FT. (Below, above) GROUND SURFACE

PUMPING WATER LEVEL: 25 FT. BELOW GRADE

AFTER 5 HOURS AT 20 GPM.

WELL HEAD COMPLETION:

TYPE: PITLESS ADAPTOR

OTHER

12 INCHES ABOVE GRADE.

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE 7

RATED CAPACITY (GPM) _____

PUMP INTAKE SETTING _____ FT. BELOW GRADE

THE COMPLETED WELL IS?

YES NO
A. AT LEAST 15' FROM ANY FOUNDATION
B. AT LEAST 50' FROM ANY SEPTIC TANK
C. AT LEAST 10' FROM TOWN SEWER LINE
D. AT LEAST 100' FROM THE NEAREST EDGE
OF ANY TILE FIELD

THE NEAREST NEIGHBORS (CIRCLE ONE)


SEPTIC TILE FIELD CESSPOOL OR PRIVY

IS _____ FROM COMPLETED WELL.

IS COMPLETED WELL LOCATED AS SHOWN

ON APPLICATION FORM?

IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.



DRILLERS LOG DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA
TOPSOIL	0	1
FINE TAN SAND	1	4
TAN CLAY & FINE SAND	4	7
CRS TAN SAND	7	18
GRAVEL & CRS TAN SAND	18	20
CRS DARK TAN SAND	20	30
TAN SAND	30	45
LIGHT TAN SAND	45	47
CRS DARK TAN SAND	47	55

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF 1 PAGES
COMPANY NAME LIFETIME WELL DRILLING CO.
SIGNATURE OF DRILLER IN CHARGE: William Kenneth Wood DATE _____

WILLIAM KENNETH WOOD