

James H. Hill Contractor
13 East 3rd St.
Blades, Del.
(Jones Motor Freight job)
south of Seaford and
just east of US #13

Pd41-1

LAV

Pd41-1 307

WRD-2
7/68

RECEIVED
NOV 27 1968

STATE OF DELAWARE
WATER AND AIR RESOURCES COMMISSION
Water Resources Division
Dover, Delaware 19901

STATE OF DELAWARE
WATER RESOURCES DIVISION

WELL COMPLETION REPORT

- 1. Permit Number: _____
- 2. Well Depth 60 ft.
Date Completed Sept 24, 1968
- 3. Grout: Type _____
from _____ ft. to _____ ft.
- 4. Casing:
2 in. to 56 ft.
_____ in. to _____ ft.
Drive shoe? Yes ___ No L
- 5. Screen:
56 ft. to 60 ft.
- 6. Well Head Completion:
_____ Pitless Adapter
12 inches above grade
- 7. Static Water Level:
13 feet below grade
- 8. Pumping Level:
3 ft. after 4 hrs.
at 40 GPM
- 9. Type of Permanent Pump:
Reciprocating ___ Jet ___
by others
Submersible ___ Other ___
Capacity: _____ GPM
- 10. If well was electric or gamma logged submit copies of the log with this report.

Formation	Thickness of Stratum	Depth to bottom of Stratum
fine and medium yellow sand	5	5
white sand and clay	10	15
light yellow sand	18	33
yellow fine and medium sand and clay	9	42
silt and fine yellow sand	13	55
fine to coarse light yellow sand	5.5	60
below 60'		
silt and fine yellow sand		

- 12. Well Number _____
(leave blank)
- 13. Signature of Water Well Contractor
Paul E. White
Date Oct 7, 1968