

WELL COMPLETION REPORT

PERMIT NO. 68569 LOCAL NO. 14

OWNER Richard Z. Leonard

CONSTRUCTION DATE 31/14/87
PURPOSE: TEST PERMANENT

- USE:
- DOMESTIC
 - COMMERCIAL
 - IRRIGATION
 - MONITOR
 - HEAT PUMP RECHARGE
 - OTHER (Specify)
 - AGRICULTURAL
 - INDUSTRIAL
 - PUBLIC
 - DEWATERING
 - HEAT PUMP SUPPLY

IS THIS A REPLACEMENT WELL? YES NO
ABANDONMENT DATE FOR OLD WELL: 11/14/87
ABANDONMENT METHOD: 218

- DRILLING METHOD
- AUGERED
 - DRIVEN
 - MUD ROTARY
 - OTHER (Specify)
 - BONED
 - JETTED
 - REVERSE
 - CABLE TOOL
 - AIR ROTARY
 - WASHED
- TOTAL DEPTH DRILLED: 70

CASING SEQUENCE

DEPTH	DIA.
50	4"
70	4"

SCREEN SEQUENCE

DEPTH	DIA.
60	4"
70	4"

GROUT TYPE: CEMENT BENTONITE CLAY
OTHER: _____
FROM 0 TO 20 FEET
NON-GROUT BACKFILL OF WELL ANNULUS
TYPE 1/4 FROM _____ TO _____ FEET
GRAVEL PACK: TYPE 2 mesh
FROM 40 TO 70 FEET
STATIC WATER LEVEL: DATE 8/14/87
1 FT. (Below, above) GROUND SURFACE
PUMPING WATER LEVEL: 33 FT. BELOW GRADE
AFTER 1 HOURS AT 100 G.P.M.

WELL HEAD COMPLETION
TYPE: FITLESS / ADAPTOR
OTHER
12 INCHES ABOVE GRADE

TYPE OF PERMANENT PUMP INSTALLED:

PUMP MANUFACTURE: N/A
RATED CAPACITY (G.P.M.): N/A
PUMP INTAKE SETTING: _____ FT. BELOW GRADE
THE COMPLETED WELL IS:
A. AT LEAST 5' FROM ANY OVERHANG YES NO
B. AT LEAST 50' FROM ANY SEPTIC TANK YES NO
C. AT LEAST 10' FROM TOWN SEWER LINES YES NO
D. AT LEAST 100' FROM THE NEAREST EDGE OF ANY TILE FIELD YES NO

THE NEAREST NEIGHBORS (CIRCLE ONE)
 SEPTIC TILE FIELD CESSPOOL OR PRIVY
70 FT. FROM COMPLETED WELL.
IS COMPLETED WELL LOCATED AS SHOWN ON APPLICATION FORM?
IF NO, DESCRIBE LOCATION CHANGE OR OTHER COMMENTS.

RECEIVED

AUG 20 1987

WATER SUPPLY

DRILLERS LOG DESCRIPTION TOP OF STRATA BOTTOM OF STRATA

top soil	0	10
white sandstone	10	20
gray sandstone	20	40
red sandstone	40	56
blue sandstone	56	70

SUPPLEMENTAL DRILLERS LOG ATTACHED YES NO
PAGE 1 OF 2 PAGES
COMPANY NAME: Delaware Drilling
SIGNATURE OF DRILLER IN CHARGE: Kenneth DeBelle DATE: 8/14/87

WHITE - OWNER

CANNARY - CONTRACTOR

PINK - OWNER

WATER DIVISION
P.O. BOX 400
UNION, WISCONSIN 53190

CASING
CASING
CASING
CASING

SCREEN
SCREEN
SCREEN
SCREEN

GROUT
OTHER
NON-GROUT
TYPE

GRAVEL PACK
CRACK
STATIC WATER LEVEL
35 FT

PUMPING
AFTER
WELL HEAD
TYPE FITLESS
OTHER

12 INCH

DOCUMENT NO.