

TO:

WATER SUPPLY SECTION  
DIVISION OF WATER RESOURCES  
89 KINGS HIGHWAY  
DOVER, DELAWARE 19901  
PHONE: 302-739-3665  
FAX: 302-739-2296

STATE OF DELAWARE  
DEPARTMENT OF NATURAL RESOURCES  
AND ENVIRONMENTAL CONTROL

WELL COMPLETION REPORT MUST  
BE RETURNED WITHIN 30 DAYS OF  
CONSTRUCTION DATE

FORMATION LOG

*Pd51-19*

PAGE 2 OF 2 PAGES

PLEASE PRINT OR TYPE - ILLEGIBLE OR INCOMPLETE FORMS WILL BE RETURNED

PERMIT# 167782		LOCAL ID#	
PROPERTY OWNER Laurel Village Trailer Park			
WELL CONTRACTOR Atlantic Well Drilling, Inc.		LIC# 789	
DESCRIPTION	TOP OF STRATA	BOTTOM OF STRATA	
Top soil	0	1	
Fine to medium white sand with white clay <u>layers</u>	1	22	
Fine to medium brown sand	22	39	
Iron ore <i>Tbd</i>	39	41	
Fine to course brown sand with white clay	41	45	
<u>White clay</u>	45	55	
Fine tan sand	55	66	
Fine to medium tan sand <i>Tb + ?</i>	66	96	
<i>see Pd53-13 log</i>			

OTHER COMMENTS:

I HEREBY AFFIRM THE INFORMATION I HAVE SUBMITTED IS ACCURATE AND CORRECT

*Edward L. Kelley Jr.* 62 10/26/99  
Signature of Well Driller In Charge License# Date