

STATE OF DELAWARE
 WATER AND AIR RESOURCES COMMISSION
 Water Resources Division
 Dover, Delaware 19901

WRD-2
 7/69

WELL COMPLETION REPORT

1. Permit Number: 36931
 Owner of Well: Herald Crapier

2. Test Well
 Observation Well
 Production Well
 Well Abandoned? Yes No

3. Total Well Depth 47 feet
 Date Completed 9-20-76

4. Casing: Type Cement
 from 3 feet to 15 feet
 from feet to feet

5. Casing: Type PVC
0 inches to 37 feet
 inches to feet
 Drive Shoe? Yes No

6. Screen Setting:
37 feet to 47 feet

7. Gravel Packed? Yes No
35 feet to 47 feet

8. Well Head Completion:
No Picless Adapter Type
 inches above grade

9. Static Water Level:
6 feet below grade
 feet above grade

10. Pumping Water Level:
15 feet below grade after
1 hours at 80 GPM

11. Permanent Pump Installed?
 Yes No
 a. Shallow Well
 Deep Well
 b. Reciprocating Rotary
 Centrifugal Jet
 Submersible
 c. Capacity GPM

12. Well Number
 (Leave Blank)

13. Well Log

Pe51-11

Formation	Thickness of Stratum	Depth to Bottom of Stratum
black dirt	0	2
black silty clay	2	3
wh. sand - Med.	3	17
brn sand - Med.	17	30
wh. sand - Med.	30	36